

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
Raiganj, College Para, Pin - 733134**

Memo No : IND/WB/FES/20192020/53926

DATE: 26/08/2019

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**Techno India Group Public School Raiganj
Mouza- Gobindapur, J.L No-172, Kh No-694(LR), Plot No-
1121,1122,1126,1127,1122/1520,1122/1521,1122/1578, P.S- Raiganj, Dist- Uttar Dinajpur
Dalkhola F.S., Raiganj,
North Dinajpur - 733134 .**

**Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction
of G + 3 storied building under group Educational at the premises no.- Mouza-
Gobindapur, J.L No-172, Kh No-694(LR), Plot No-
1121,1122,1126,1127,1122/1520,1122/1521,1122/1578, P.S- Raiganj, Dist- Uttar Dinajpur,
Raiganj, North Dinajpur - 733134**

This is in reference to your Application No. IND/WB/FES/20192020/53926, dated 26/08/2019, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 3 storied building under group Educational at the premises no. - Mouza- Gobindapur, J.L No-172, Kh No-694(LR), Plot No- 1121,1122,1126,1127,1122/1520,1122/1521,1122/1578, P.S- Raiganj, Dist- Uttar Dinajpur, Raiganj, North Dinajpur - 733134.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.


Principal
Techno India Group Public School
Raiganj, Uttar Dinajpur


Manager
Techno India Group Public School
Raiganj

1. 1) Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
- 2) Entrance / Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
- 3) The interior finish decoration of the building shall be made with low flame spread materials confirming to the I.S Specification.
- 4) To eliminate risk of Fire Hazard, good house keeping both for insides and outsides of the building shall be strictly maintained.
- 5) Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly line above false ceiling and ducts.
- 6) The employee and security staffs shall be conversant with installed fire fighting equipments of the building and to operate in the event of fire and testing.
- 7) Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 8) First aid fire fighting system shall be provided as per I.S specification.
- 9) Arrangement shall have to be made for regular checking, testing, and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.
- 10) If require the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S conduit pipes continuously bonded to the earth.
- 11) All the pumps and detection system which are incorporated in the building shall be kept in auto mode round the clock.
- 12) The fire safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.
- 13) The Fire safety certificates is valid for Three years and has to be renewed after three years from the date of issue of this letter.
- 14) This certificates is to be obtained from the Director General, West Bengal Fire and Emergency Services regarding performance of all the fire safety arrangements and installing of the building.

Signature valid

Digitally signed by DEWAN
LEPCHA
Date: 2019.08.26 02:28:58 PDT

Divisional Fire Officer
West Bengal Fire & Emergency Services


Principal

Techno India Group Public School
Raiganj, Uttar Dinajpur


Manager
Techno India Group Public School
Raiganj